

## The Ten Commandments of Good Battery Care

- 1) Add approved water only - never add acid.
- 2) Keep electrolyte level above separator protectors.
- 3) Keep battery top clean and dry.
- 4) Keep flame and metal away from battery top.
- 5) Keep vent caps tightly in place.
- 6) Discharge 80% only and do not operate battery if the specific gravity is below 1.150 for POWERLINE, VARTA, WATERLESS, and TOP POWER, and 1.175 for ENERGY-PLUS.
- 7) Cool before charging or operating if battery is above 115° F.
- 8) User only approved charger of correct voltage and current output.
- 9) Keep truck compartment and battery cover open during charging.
- 10) When in doubt, call you CISCO service representative for long, reliable battery life.

## Watering Instructions

### Approved Water

In most areas of the United States, tap water is satisfactory for use in lead acid batteries. Use distilled water when in doubt.

### Proper Electrolyte Level

The electrolyte level must be kept between the "High Watering Level" and the separator protectors shown in the sketch below. The batteries should be filled only at the end of the chargin cycle.

**CAUTION - DO NOT OVERFILL!**

**Moisture on the TOPS of the batteries indicates overfilling has occurred.**

